




Ministry of Defence

Adrian Lynham
Dorset Council
Minerals & Waste Planning Team
County Hall
Colliton Park
Dorchester
Dt1 1XJ

Defence Infrastructure Organisation

Safeguarding Department
Statutory & Offshore
Defence Infrastructure Organisation
Kingston Road
Sutton Coldfield
West Midlands
B75 7RL



Your reference: WP/20/00692/DCC
Our reference: 10051102

www.mod.uk/DIO

11 May 2021

Dear Adrian,

MOD Safeguarding

Proposal: Construction of an energy recovery facility with ancillary buildings and works including administrative facilities, gatehouse and weighbridge, parking and circulation areas, cable routes to ship berths and existing off-site electrical sub-station, with site access through Portland Port from Castletown

Location: Portland Port, Castletown, Portland

Grid Ref:

Easting	Northing
368,998	074,438
369,438	074,278
370,092	074,437
369,766	074,057
368,841	074,360
368,965	074,849
369,430	074,718
369,260	074,592

Thank you for consulting the Ministry of Defence (MOD) on the above development which was received by this office on 11/03/2021.

The applicant is seeking full planning permission for the construction of an energy recovery facility with ancillary buildings and works including administrative facilities, gatehouse and weighbridge, parking and circulation areas, cable routes to ship berths and existing off-site electrical sub-station, with site access through Portland Port from Castletown.

After reviewing the documents provided, I can confirm that the MOD have no objections to this proposal.

Whilst we have no safeguarding objections to this application, In the interests of air safety, the MOD requests that the mast is fitted with aviation warning lighting. The mast should be fitted with a minimum intensity 25 candela omni directional flashing red light or equivalent infra-red light fitted at the highest practicable point of the structure.

I trust this is clear however should you have any questions please do not hesitate to contact me.

Yours sincerely

Kalie Jagpal
Assistant Safeguarding Manager